




Fukushima Daiichi NPP



April 21 2011, Ki Sig Kang

Tsunami Phenomenon





Earthquake and affected NPPs



	Automatic Shutdown	Inspection Outage
Higashidori	-	Unit 1
Onagawa	Units 1-3	-
Fukushima Daiichi	Units 1-3	Units 4-6
Fukushima Daini	Units 1-4	-
Tokai Daini	(only 1 unit)	-
	11 Units	4 Units

11 Units (BWRs) under operation were successfully shutdown after the earthquake occurred at 14:46 (06:46) of 11 March 2011

Fukushima Daiichi NPP

Unit	Output (MW)	Start Operation	Manufacturers
No.1	460, BWR-3, 400 FA (68T, UO2)	1971/3	GE
No.2	784, BWR-4, 548 FA (94T, UO2)	1974/7	GE/Toshiba
No.3	784, BWR-4, 548 FA (95T, MOX)	1976/3	Toshiba
No.4	784, BWR-4, 548 FA (94T, UO2)	1978/10	Hitachi
No.5	784	1978/4	Toshiba
No.6	1100	1979/10	GE/Toshiba
Total	4696		

13 Emergency Diesel Generators, each unit has 2 DG, but No.6 has three DG(one- air cooled)

5

Fukushima 1 Npp unit 1 ~ 4







Dai Ino NPS before Tsunami




Dai Ini NPS after Tsunami




March 28 1979

**1987
End State
Configuration**



April 26 1987
Chernobyl 4 Destroyed




13

Molten Fuel – Elephant Foot



14



A lot of equipment will be placed inside the “Arch”,
i.e. lifting cranes, mechanisms and other industrial
facilities..




15

BWR information

16

Mark 1 Containment Fukushima Daiichi #1




RPV : 19.7 m
 RPV In-dia: 4.8 M
 RPV Thick: 16 Cm
 Fuel : UO₂
 Refuelling : 13 M
 FA : 400
 FA length : 3.66 m
 Operation Press. : 70.7 bar
 Operation Temp : 285 oC
 Thermal Power : 1380 MWt
 Elec. Power : 460 Mwe
 Turbine : 1500 RPM
 Cont. Pressure : 4.3 bar
 Total vol : 3410 M3
 HP sys Press : 19 bar
 SPF capacity : 900 FA



Const : 1967 7.25
 COD : 1971.03.26

DRYWELL TORUS


17



18





BWR Design Features – small primary containment housed in large building



Upper part of Reactor Vessel - Service Floor



BWR Mark I Containment



Reactor Vessel Assembly

- Vessel
- Fuel Assembly and Control Rods
- Recirculation Jet Pump Assembly
- Core Support Structure
- Steam separator (dryer)
- Core Shroud






Figure 6-1. Schematic cross-section of a Pressurized Water Reactor. In a Pressurized Water Reactor, the water in the primary loop circulates through the reactor vessel. Water passes through the core, heating it up to the boiling point. Water that boils is not converted to steam, but is pumped back to the vessel through the action of "jet pumps" which surround the core (see text). (Figure reproduced from "Nuclear Energy")


Normal Operation



Decay Heat Removal (with electric power)




Normal Cooling using Reactor Core Isolation Cooling (without electric power - 8 hr)




Number of Npp Units : 443

(as of Dec 2010)




Reactor Building Arrangement

BWR Mark 1



PWR PCCV*



* Pre-stressed Concrete Containment Vessel

Comparison of Design Features

Parameters	PWR	BWR
Steam Production	Secondary System Steam Generator	Directly in the System
Pressure	Varies, 15.5 Mpa Controlled by Pressurizer	Constant, 7.2 Mpa
Produced steam	Goes through steam generators then to turbine; nonradioactive	Goes through separators and steam dryers then to turbine; radioactive
Zircaloy mass of Fuel assembly	Relatively Small	Relatively Large Larger quantities of H ₂ generated
Containment Building	Large Volume for non-condensable gas retention,	Small Volume, Minimal capacity for non-condensable gas retention,
Gen III, Gen III+ reactors	AP-1000, EPR, VVER-1200, APR- 1400, APWR	ABWR, ESBWR


Engineering Review of Accident Sequences

Verification of the design Tsunami

Consideration of Tide

The Design Tsunami

- Maximum water ascent
- Maximum water decent




Tidal Conditions

Design High Water Level

= 10 M


= Maximum water ascent + Mean of high tides + Safe Margin

Tsunami Evaluation Method for Nuclear Power Stations in Japan, SAKAI Toshiaki- TEPCO




= * Other Npps
13 M (DG- active)


Major Root Cause of the Damage




Fukushima Daiichi Accident Process




Fukushima Daiichi Accident Process




Fukushima Daiichi Accident Process




Fukushima Daiichi Accident Process




Fukushima Daiichi Accident Process




Fukushima Daiichi Accident Process



Fukushima Daiichi Accident Process



Fukushima Daiichi Accident Process



Radiological Impacts

43

Typical BWR spent fuel pool



- Cooling (3MW)
- Shielding
- Preventing criticality
- About 12m x 12m x 12m
- Concrete thickness is about 1.2 – 2.4 m with a 6 -13 mm steel liner
- Dense fuel racks







Monitoring locations near Fukushima site

- 1) Measurement of air dose rate, 2) Measurement of cumulative dose
- 3) Measurement of radioactive substance concentration in soil
- 4) Offshore monitoring, 5) Aerial monitoring



Radiology

Radioactivity released from March 11 to 20, 2011



Cumulative dose for an unprotected one year old child

Extended Tepco Limit: 250 mSv

Initial Tepco Limit: 100 mSv, Maximum Allowed 50 mSv/a,

0.01 mSv: x-ray image in dental care

0.1 mSv: a x-ray image from lungs

2 mSv: flight attendances got from cosmic radiation every year

3.7 mSv: typical background radiation level in EU

20 mSv: dose from computer tomography

50 mSv: dose limit for radiation worker

3000~6000 mSv: fatal dose

Tokyo : 0.1 mSv

Site work and Future plan

Current Priorities

- Six Project Teams have been established under the Integrated Headquarters:
 - 1) Radiation Shielding/Radioactive Materials Release Reduction
 - 2) Defuelling /Fuel Transportation
 - 3) Remote Monitoring/Sampling
 - 4) Long Term Cooling Circuit Establishment
 - 5) Contaminated Water Management
 - 6) Environmental Impact evaluation

- TEPCO's current priorities are on 4) and 5), and on Power System Recovery, which is the basis of all activities.


Future Plans

TEPCO Chairman's Announcement on 17 April

- The 1st Stage (3 months):
 - Cool the reactors in a stable manner; and
 - Prevent water with high levels of radioactivity from flowing out of the plant.
- The 2nd Stage (6 to 9 months):
 - Achieve a cold shutdown of the reactors; and
 - Reduce the total amount of radioactive water.



Chief Cabinet Secretary approved the plan as “sufficiently feasible”.




Safety Assessments as a result of the Fukushima Accident

- Stress Tests Proposed by EU
 - Earthquake, flooding and other external events exceeding design basis
 - Prolonged loss of power and/or ultimate heat sink
 - Combination of above plus multiple units effected simultaneously
 - Accident management, including core melt down and loss of shielding of the spent fuel pools
 - Finalized in 2011



- Impact of stress tests on additional NDT
- Any other developments that may impact on the role of NDT

Challenges and Opportunities



N and S Poles

- Opposite poles of the magnet
- Do not exist separately.
- Opportunity for some can be a challenge for others,
- Challenge today can become an opportunity tomorrow

All these world challenges will increase the opportunities to strengthen the achievements in Nuclear Power Development